

Name of the company	Location
Example	USA
simon geisshuesler	NY Albany
Stadthausstrasse 115	Longitude: -73.8°
8640 winterthur	Latitude: 42.75°
001 (697) 346 23 46	Elevation: 200 ft

**Overview**

End energy to the system (fuel and electricity)	11473.4 kBtu
Energy consumption (Q <sub>use</sub> )	34115.4 kBtu
Syst. efficiency (End energy / Energy consumption)	2.97
Comfort demand	Energy demand covered

**Overview heat pump**

Seasonal performance factor	3.8
Ground loop length (Total)	393.7 ft
Energy withdrawal	26784.2 kBtu

**Meteorological data**

Outdoor temperature	48.8 °F
Global irradiance	435.6 kBtu/ft <sup>2</sup>
Diffuse irradiance	199.9 kBtu/ft <sup>2</sup>


## System overview

<b>B/W or W/W heat pump 2</b>		<b>Water-water heat pump 10 kW</b>	
Seasonal performance factor			3.8
CO emissions	pound		3544.5
End energy	kBtu		10227.2
<b>Ground-source loop 3</b>		<b>25 mm double U ground loop</b>	
Ground loop length	ft		394
Number of ground-source loops			1
Earth layer 1			Dry gravel
Inflow temperature	°F		39.6
EWT Outflow temperature	°F		48.2
Energy withdrawal	kBtu		26784.2
<b>Building</b>		<b>Single family house, low-energy building</b>	
Heated living area	ft <sup>2</sup>		1612
Heating setpoint temperature	°F		66.2
Heating energy demand	kBtu		23147.3
Specific heating energy demand	kBtu/ft <sup>2</sup>		14.4
Solar gain through windows	kBtu		59076.6
Total energy losses	kBtu		105459.4
<b>Convactor</b>		<b>Floor heating 1000W</b>	
Number of modules	-		8
Power per heating module under standard conditions	kBtu/hr		3.41
Nominal inlet temperature	°F		104
Energy from/to the system	kBtu		23076
<b>Hot water demand</b>		<b>Constant</b>	
Withdraw volume	gal/d		53.4
Temperature setting	°F		122
Energy demand	kBtu		10509.1
<b>External heat exchanger</b>		<b>Plate heat exchanger, medium size</b>	
Transfer capacity	W/K		10000
<b>Pump 4</b>		<b>Pump, medium</b>	
Circuit pressure drop	psi		0.386

Flow rate	gal/h	211.3
End energy	kBtu	200.7
<b>Pump 5</b>	<b>Pump, medium</b>	
Circuit pressure drop	psi	0.409
Flow rate	gal/h	211.3
End energy	kBtu	519
<b>Pump 7</b>	<b>Pump, medium</b>	
Circuit pressure drop	psi	9.912
Flow rate	gal/h	528.3
End energy	kBtu	526.5
<b>Storage tank 5</b>	<b>300l potable water tank</b>	
Volume	gal	79.3
Height	ft	3.94
Material		Stainless steel
Insulation		Rigid PU foam
Thickness of insulation	in	3.15
Heat loss	kBtu	881
Connection losses	kBtu	631


## Auxiliary energy to the system [Qaux]

kBtu



## End energy to the system (fuel and electricity) [Etot]

kBtu



Year	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
------	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

### Auxiliary energy to the system [Qaux]

kBtu	38867	9214	5569	3871	1583	1207	1169	1207	1170	1133	1177	3474	8094
------	-------	------	------	------	------	------	------	------	------	------	------	------	------

### Auxiliary energy (end energy) [Eaux]

kBtu	10227	2453	1444	1014	431	341	330	341	332	322	334	874	2011
------	-------	------	------	------	-----	-----	-----	-----	-----	-----	-----	-----	------

### End energy to the system (fuel and electricity) [Etot]

kBtu	11473	2728	1613	1137	489	389	376	388	378	366	381	982	2246
------	-------	------	------	------	-----	-----	-----	-----	-----	-----	-----	-----	------

### Parasitic energy (end energy) [Epar]

kBtu	1246	275	169	123	58	48	46	47	46	45	47	107	235
------	------	-----	-----	-----	----	----	----	----	----	----	----	-----	-----

### Energy consumption [Quse]

kBtu	34115	8591	5058	3434	1301	963	920	936	921	879	904	2985	7222
------	-------	------	------	------	------	-----	-----	-----	-----	-----	-----	------	------

Year	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
<b>Heat loss to indoor room [Qint]</b>													
kBtu	3307	425	314	294	231	227	221	230	230	224	233	282	396